



ANALYSIS REPORT

Page 01 of 01

Ref.NoENV/05-2023/372

Date: 02.06.2023

Name and address of the customer : **M/s.M A M BETHANY PUBLIC SCHOOL,
KUMILY, 1st MILE, IDUKKI DIST.**

Particulars of the sample : **WATER SAMPLE.**

Date of receipt of sample : **31.05.2023**

Standard Referred : **IS 3025**

Sl NO	PARAMETERS	UNIT	TEST METHOD	RESULT	LIMIT
1	pH	pH Units	APHA	6.8	6.5 – 8.5
2	Odour	-	APHA	Unobjectionable	Unobjectionable
3	Turbidity	NTU	APHA	2.9	5.0
4	Total Hardness(asCaCO3)	mg/L	APHA	13	200.0
5	Calcium as Ca	mg/L	APHA	08	75.0
6	Magnesium (as Mg)	mg/L	APHA	04	30.0
7	Total alkalinity(asCaCO3)	mg/L	APHA	12	200.0
8	Chlorides (as Cl)	mg/L	APHA	15	250.0
9	Sulphates (as SO4)	mg/L	APHA	03	200.0
10	Nitrates (as NO3)	mg/L	APHA	Absent	45.0
11	Iron (as Fe)	mg/L	APHA	0.08	1.0
12	Total Dissolved Solids	mg/L	APHA	52	500
MICROBIOLOGICAL ANALYSIS					
13	Coli form Count	MPN/100ml	IS 5401	<2	<2
14	E.coli	Absent/Present	IS 1622	Absent	Absent

*Remark : Sample conforms to IS 10500 specifications for drinking water based on above tests conducted.

Sa. Parashilhas S.J.C

Manager

MAM Bethany Public School
Kumily - 685509

< End of Report >

ENVIRONMENTAL SERVICES
Azad Building, Azad Road
Kaloor, Kochi-17
Phone 0484 6242442, 2333265
mail enviroqc@gmail.com

Bilal

ANALYST

Sobana
Principal
MAM Bethany Public School
Kumily

Analysis of Food Products • Industrial Chemicals • Tea • Spices • Oils & Fats etc...

• Drinking Water Analysis • Effluent Water Analysis • Microbiological Analysis • EIA & EMP Preparation • Stack Monitoring
• Ambient Air Quality Monitoring • Sound Level Monitoring • Soil Analysis and Other Pollution Testing...

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 156/23

Dated: 12/6/2023

It is certified that an inspection team headed by R.E.J. JOSEPH Health Inspector

(Name of Officers with designation) from P.H.C. Kumily

(Name of Department/ Office) inspected the M.A.M. Bethany Public School

(Name & Address of the school) on 6/6/2023 (date of inspection) and found that the M.A.M. Bethany (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 2023-2024.

Signature with Seal: Reji Joseph

Name: R.E.J. JOSEPH

Designation: Health Inspector

Name & Address of the Office / Department: P.H.C. Kumily

HEALTH INSPECTOR
P. H. CENTRE
KUMILY.M.A.M. Bethany Public School
Kumily

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Dr. Praeshilth S.J.C
Manager
M.A.M. Bethany Public School
Kumily - 685509

Dr. Seema
Principal
M.A.M. Bethany Public School
Kumily